



TSSPDCL

Order Type : PM66
Net Metering Order

Order release date :

PM Order Number : 966000002057

PM Order Generation Date : 03.12.2016

Name of the Work : M/S. TEJA EDUCATIONAL SOC

Status of the Order : CRTD PRC MANC

Work Description

General Data:

Name of the Officer :

Responsible Office : 11421300 - ADE/OP/GATKESAR

Estimated Cost : 6,767.00

Scheme under which sanctioned : RR East Circle Net Metering Sch-2014

PM Order Issued with Amount:

Material : Rs 6,767.00

Total : Rs 6,767.00

Geethanjali
T/c Electrical
maintenance.

Site
Geethanjali
Geethanjali College of Engg. and Tech.
Cheerayal (V), Keerasa (M), Medchal Dist.(T.S.)-501 301.

[Signature]
Authorized Signature with
Assistant Divisional Engineer
Operation, Ghatkesar
RR East Circle, TSSPDCL



TSSPDCL

PM Order Number : 966000002057
Name of the Work : M/S. TEJA EDUCATIONAL SOC
Reservation Number : 8001216383
Purchase Requisition No :

List of Materials:

Material	Material Description	Qty	Units	Rate/ Unit	Amount
MTN3 0004	11KV HTTVR 10/5A,0,2S Class (Net Meters)	1	EA	6,767.00	6,767.00
				Total	6,767.00

[Signature]
Authorized Signature with Seal
Assistant Divisional Engineer
Operation Division
W.R. East Circle, TSSPDCL

C. Praveen
H/O Electrical
Maintenance.

[Signature]
PRINCIPAL
Geethanjali College of Engg. and Tech.
Cheerayal (V), Keesara (M), Medchal Dist.(T.S.)-501 301

NETE MTER Solar Generating Unit Synchronisation Report/Test Report

A Application Details		
1	Net Meter Registration Number	NT908161642
2	Registration Date	18.11.2016
3	Name of the applicant	M/s Teja Educational Society
4	Service Number	HBG-2780 (Old RRE-2780)
5	Category	II
6	Load	150KW
7	Distribution/Section	Keesara
8	Pole Number	6
9	Address	Sy.No 31, Cheeryala, Keesara
10	Mobile Number	8919641712
B Old Meter Details		
1	Meter Make	L&T
2	Serial Number	9575145
3	Capacity	PTR:11KV/110V, CTR:10/5A
4	MF	1
5	Final Reading	
	KWH	1074496
	KVAH	1142046
	KVA	130.06
	RC	6
	TOD's	
	C1	334396
	C2	147874
	C5	140708
	C6	68207
6	Date of replacement	10.11.2017
C New Net Meter Details		
1	Meter Make	HPL
2	Serial Number	641041
3	Capacity	PTR: 11KV/110V, CTR: -/5A
4	MF	2
5	Meter Constant	
6	Intial Reading (Tri Vector Paramenters)	
Imports		
	KWH	33.1
	KVAH	43.1
	KVA	0

G. Prasad
 I/c Electrical
 maintenance

PRINCIPAL
 Geethanjali College of Engg. and Tech.
 Cheeryal (V), Keesara (M), Medchal Dist.(T.S.)-501 301.

	RC	0
	TOD's	
	C1	0
	C2	0
	C5	41.9
	C6	0
	Export	
	KWH	5.1
	KVAH	5.3
	KVAH	0
	RC	0
	TOD's	
	C1	0
	C2	0
	C5	4.5
	C6	0
D	Details of Protective System Available (Commissioning shall be done only on availability of the protective equipment)	
E	Date of Synchronisation/Grid Connection	10-11-17

CERTIFICATE

It is certified that there is no return voltage from the inverter to the meter when incoming grid supply is switched off

It is further certified that the protective equipment is installed and functioning as prescribed.

MAI
Agent Signature
Hyderabad
FOUR SOLAR ENERGY SYSTEMS PVT. LTD.

Teja Educational Society
RW
Consumer Signature
Secretary

Alcy
Assistant Division Engineer
ASSISTANT DIVISIONAL ENGINEER
Operation/Keesara Sub-Division
OPERATION KEESARA
RR EAST CIRCLE, TSSPDCL.

AD
Divisional Engineer
Operation/Keesara Division
Teja Educational Society
Hyderabad

DIVISIONAL ENGINEER
Operation Keesara
R.R.East, TSSPDCL

Chinandi
I/c Electrical
Maintenance

S/A
PRINCIPAL
Geethanjali College of Engg. and Tech.
Ghantatal (V), Keesara (M), Madhwal Dist. (T.S.)-501 301



TSSPDCL

Order Type : PM66
Net Metering Order

Order release date :

PM Order Number : 966000002056

PM Order Generation Date : 03.12.2016

Name of the Work : M/S. TEJA EDUCATIONAL SOC

Status of the Order : CRTD PRC MANC

Work Description

General Data:

Name of the Officer :

Responsible Office : 11421300 - ADE/OPI/GATKESAR

Status of the Order : CRTD
Estimated Cost : 6,767.00

Scheme under which sanctioned : RR East Circle Net Metering Sch-2014

Work Description

PM Order Issued with Amount:

Material : Rs 6,767.00

Total : Rs 6,767.00

G. Srinani
E/E Electrical
Maintenance

SAB

PRINCIPAL
Geethanjali College of Engg. and Tech.
(Ghantyal (V), Keesara (M), Madhwal Dist.(T.S.)-501 301

Authorized Signature with
Assistant Divisional Engineer
Operation, Ghatkesar
RR East Circle TSSPOC



TSSPDCL

PM Order Number : 966000002056
Name of the Work : M/S. TEJA EDUCATIONAL SOC
Reservation Number : 8001216381
Purchase Requisition No :

List of Materials:

Material	Material Description	Qty	Units	Rate/ Unit	Amount
MTN30004	11KV HTTVR 10/5A.0.2S Class (Net Meters)	1	EA	6,767.00	6,767.00
				Total	6,767.00

Authorized Signature with Seal

Assistant Divisional Engineer

Operation, Ghatkesar

RR East Circle, TSSPDCL

G. Srinivas
I/E Electrical
Maintenance

S. Ho
PRINCIPAL
Geethanjali College of Engg. and Tech.
Cheerayal (V), Keesara (M), Medchal Dist.(T.S.)-501 301

NETE MTER Solar Generating Unit Synchronisation Report/Test Report

A Application Details		
1	Net Meter Registration Number	NT908161643
2	Registration Date	18.11.2016
3	Name of the applicant	M/s Teja Educational Society
4	Service Number	HBG-1682 (Old RRE-1682)
5	Category	II
6	Load	100KW
7	Distribution/Section	Keesara
8	Pole Number	6
9	Address	Sy.No 31, Cheeryala, Keesara
10	Mobile Number	8919641712
B Old Meter Details		
1	Meter Make	L&T
2	Serial Number	16283664
3	Capacity	PTR:11KV/110V, LTR:10/5A
4	MF	1
5	Final Reading	
	KWH	132858
	KVAH	134612
	KVA	75.942
	RC	31
	TOD's	
	C1	20054
	C2	18507
	C5	14951
	C6	7585
6	Date of replacement	10.11.2017
C New Net Meter Details		
1	Meter Make	HPL
2	Serial Number	641018
3	Capacity	PTR: 11KV/110V, CTR: -/5A
4	MF	2
5	Meter Constant	
6	Intial Reading (Tri Vector Paramenters)	
	Imports	
	KWH	29.2
	KVAH	39
	KVA	0

G. Prasad
The Electrical
Maintenance

PRINCIPAL
Geethanjali College of Engg. and Tech.
Cheeryal (V), Keesara (M), Medchal Dist.(T.S.)-501 301

	RC	0
	TOD's	
	C1	0
	C2	0
	C5	37.6
	C6	0
	Export	
	KWH	5
	KVAH	5.3
	KVAH	0
	RC	0
	TOD's	
	C1	0
	C2	0
	C5	4.5
	C6	0
D	Details of Protective System Available (Commissioning shall be done only on availability of the protective equipment)	
E	Date of Synchronisation/Grid Connection	10-11-17

CERTIFICATE

It is certified that there is no return voltage from the inverter to the meter when incoming grid supply is switched off

It is further certified that the protective equipment is installed and functioning as prescribed





 Agent Signature
 Hyderabad
 Teja Educational Society
 Consumer Signature
 Secretary
 Assistant Division Engineer
 OPERATION KEESARA Sub-division
 OPERATION KEESARA
 P.R. EAST CIRCLE, TSSPDCL.
 Divisional Engineer
 Operation/Keesara Division

DIVISIONAL ENGINEER
 Operation Keesara
 P.R. East, TSSPDCL

G. Prasad
 Electrical
 Maintenance


PRINCIPAL
 Geethanjali College of Engg. and Tech.
 Cheeryal (V), Keesara (M), Medchal Dist. (T.S.)-501 301